one quarter S DE CON ISSUE .

Revisions:

VA FORM 08-6231

LIGHTING FIXTURE SCHEDULE *									
YPE	DESCRIPTION		MOUNTING	LAMPS	BALLAST	DIFFUSER	REMARKS		
FA	2' X 4' FLUORESCENT DIRECT/INDIRECT, STRAIGHT BLADE WITH ROUND HOLES.	LITHONIA #2AVG332SBL277GEB10IS OR EQUAL BY DAY-BRITE, LIGHTOLIER	RECESSED LAY-IN	3-F32T8/SP35/RS	277V ELECTRONIC	STRAIGHT BLADE LOUVER, ROUND HOLES	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FB	2' X 2' FLOURESCENT DIRECT/INDIRECT, STRAIGHT BLADE WITH ROUND HOLES.	LITHONIA #2AVG217SBL277GEB10IS OR EQUAL BY DAY-BRITE, LIGHTOLIER	RECESSED LAY-IN	2-F17T8/SP35/RS	277V ELECTRONIC	LOW IRIDESCENT ANODIZED SPECULAR	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FC	2' X 4' FLUORESCENT TROFFER-FLANGED 0.125 ACRYLIC LENSED.	LITHONIA #2SP8G332FWA12125277GEB10RS OR EQUAL BY DAY-BRITE, LIGHTOLIER	RECESSED LAY-IN	3-F32T8/SP35/RS	277V ELECTRONIC	#12 ACRYLIC 0.125" REVERSE APEX	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FC1	2' X 2' FLUORESCENT TROFFER-FLANGED 0.125 ACRYLIC LENSED.	LITHONIA #2SP8F217FWA12125277GEB10RS OR EQUAL BY DAY-BRITE, LIGHTOLIER	RECESSED	2-F17T8/SP35/RS	277V ELECTRONIC	LOW IRIDESCENT ANODIZED SPECULAR	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FD	6" HORIZONTAL DOWNLIGHT CFL WITH CLEAR TRIM LENSED	GOTHAM #AF126TRT6ARCGL277 OR EQUAL BY LIGHTOLIER, DAY-BRITE	RECESSED	1-CF26TRT 3500K	277V ELECTRONIC	SEMI SPECULAR CLEAR GLASS LENS	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FD1	6" HORIZONTAL DOWNLIGHT CFL WITH CLEAR TRIM OPEN REFLECTOR	GOTHAM #AF126TRT6AR277 OR EQUAL BY LIGHTOLIER, DAY-BRITE	RECESSED	1-CF26TRT 3500K	277V ELECTRONIC	SEMI SPECULAR NO LENS	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FE	6" HORIZONTAL DOWNLIGHT CFL WITH CLEAR TRIM OPEN REFLECTOR	FOCAL POINT #FV2SPS2T81C277SC24L835WH12 OR EQUAL BY LIGHTOLIER, DAY-BRITE	PENDENT	6-F32T8/SP35/RS	277V ELECTRONIC	PERFORATED HOUSING	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FF	4FT INDUSTRIAL FLUORESCENT, HEAVY DUTY STEEL HOUSING, DIE EMBOSSED, REFLECTOR WITH APERTURES FOR 10% UPLTG.	LITHONIA #AF10-232-GEB10IS	PENDANT	2-F32T8/SP35 3500K	277V ELECTRONIC	DIE EMBOSSED	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FG	WALL MOUNT CFL WITH DIE CAST IMPACT RESISTANT, TEMPERED GLASS LENS.	LITHONIA #TWF32TRT277VHEBLPI OR EQUAL BY LIGHTOLIER, DAY-BRITE	WALL MOUNT	1-CF32TRT 3500K	277V ELECTRONIC	TEMPERED GLASS	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FH	24" UNDERCABINET FLOURESCENT LIGHT	LITHONIA #N2S17277GEB10ISLPI OR EQUAL BY LIGHTOLIER, DAY-BRITE	UNDERCABINET MOUNT	1-F17T8/SP35/IS 3500K	277V ELECTRONIC	SHATTER RESISTANT	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
FH1	36" UNDERCABINET FLOURESCENT LIGHT	LITHONIA #N2S25277GEB10ISLPI OR EQUAL BY LIGHTOLIER, DAY-BRITE	UNDERCABINET MOUNT	1-F25T8/SP35/IS 3500K	277V ELECTRONIC	SHATTER RESISTANT	WITH ELECTRONIC BALLAST AND LESS THAN 10% THD		
X1	THERMOPLASTIC LED EXIT SIGN, SINGLE FACE, RED LETTERS, WHITE HOUSING, END/CEILING/WALL MOUNTED	SURE-LITES #CAX-610000-RW-LED	UNIVERSAL	FURNISHED WITH LUMINAIRE	277V	RED LETTERS	PROVIDE DIRECTION ARROWS AS SHOWN ON FIRE PROTECTION DRAWINGS		
X2	THERMOPLASTIC LED EXIT SIGN, DOUBLE FACE, RED	SURE-LITES #CAX-620000-RW-LED	UNIVERSAL	FURNISHED WITH LUMINAIRE	277V	RED LETTERS	PROVIDE DIRECTION ARROWS AS SHOWN ON FIRE PROTECTION DRAWINGS		
EX	EXISTING LIGHT FIXTURE TO REMAIN								
R	RELOCATED LIGHT FIXTURE.								

NOT ALL LIGHTING FIXTURES ARE USED ON THIS PROJECT.

## 1 LIGHT FIXTURE SCHEDULE SCALE: NOT TO SCALE BLD: 11

## "ISSUED FOR BIDS"-FULLY SPRINKLERED

SCHEMATIC DESIGN SUBMISSION	08/02/10	CONSULTANTS:	ARCHITECT/ENGINEERS:	
DESIGN DEVELOPMENT SUBMISSION	09/03/10	CONSOLIANTS		
CONSTRUCTION DOCUMENT SUBMISSION	11/22/10	Same,		
ISSUE FOR BIDS	12/19/11		WILSON A	RCHITECTURAL GROUP
		Extra Viving	5051 WESTHEIMER, SUITE 180	0 HOUSTON, TEXAS 77058 TELEPHONE (713) 621-8714
		FERNANDO L. PEREIRA	MEP ENGINEERS	BURNS DeLATTE AND McCC
		84894 10 10 10 10 10 10 10 10 10 10 10 10 10 1	STRUCTURAL ENGINEERS	PINNACLE STRUCTURAL
		Burns, DeLatte & McCoy, Inc.	FIRE PROTECTION ENGINEERS	PROTECTION DEVELOPMENT
Revisions:	Date	Date: Texas Registered Engineering Firm F-685	CIVIL ENGINEERS	BREWER AND ESCALANTE

COY, INC.

LIGHT FIXTURE SCHEDULE NO SCALE Approved: Project Director

Drawing Title

Project Title Project Number 674A4-CSI-516 **BUILDING 11 ADDITION AND** INTERIOR RENOVATIONS Building Number Drawing Number Location WACO, TEXAS ES600 Dwg. of Checked FP

Office of Construction and Facilities Management Department of Veterans Affairs